

2021 MAY -5 AM 8:55



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION**Consumer Confidence Report (CCR)**ACL Water Assn, Inc.

Public Water System Name

0610001 & 0610041

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	<u>May 2021</u>
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations) <u>at ACL office</u>	<u>5-3-2021</u>
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): <u>ACLwaterassociation.com</u>	<u>5-3-2021</u>

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name

Cindy Lewis

Title

Office Manager

Date

5-3-2021**SUBMISSION OPTIONS** (Select one method ONLY)**You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.****Mail:** (U.S. Postal Service)**Email:** water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

Fax: (601) 576-7800(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

PWS ID#: 0610001		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								

10. Barium	N	2019*	.0034	.0019 - .0034	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	.7	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019*	.121	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	92000	91000 - 92000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2020	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	2.06	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.9	1.1 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 0610041

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2018*	.0023	.0013 - .0023	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	2.4	1.8 – 2.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.123	.113 - .123	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	110000	98000 - 110000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2020	9	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	5.07	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.7	1 – 1.1	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Significant Deficiencies

Monitoring and Reporting of Compliance Data Violations:

During a sanitary survey conducted on 08/23/2017, the Mississippi State Department of Health cited the following significant deficiency(s):

Well near source of fecal contamination

Corrective Actions: This system is enrolled in the MSDH well abandonment program and is awaiting funds. The anticipated abandonment date is 12/31/2021.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The ACL Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



ACL WATER ASSN, INC.
1182 HWY 43 S.
PELAHATCHIE, MS 39145

RETURN SERVICE REQUESTED

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PELAHATCHIE, MS
PERMIT NO. 3

PLEASE READ NOTICE ON BACK

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	342770	335180	7,590	29.18
Walters Fire (OPTIONAL)				1.00

MAIL THIS STUB WITH YOUR PAYMENT

CUSTOMER		DUE DATE	
HOUSE	ACCOUNT	PAST DUE AFTER THIS DATE	
2	573	5/10/21	
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT	
30.18		33.10	

PLEASE SHOW METER READING HERE
034827.0

5-1-21

2508 HWY 43 SOUTH



Service From 3/1/2021 TO 4/8/2021 ACCOUNT # 573 4/27/2021

METER READ MONTH DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4 8	1	30.18	2.92	33.10

DOUGLAS NORRIS
2508 HIGHWAY 43 S
BRANDON MS 39042-8516

**2020 FINANCIAL STATEMENT AVAILABLE AT ACL AND
PELAHATCHIE PUBLIC LIBRARY**

****CCR AVAILABLE @ ACLWATERASSOCIATION.COM ON
JULY 1, 2021. HARD COPY WILL BE AVAILABLE AT ACL
OFFICE****

2021 MAY 13 AM 8:08

Cockrell, Joan

0610001

0610041

From: ACL WATER ASSOCIATION, INC. <aclwaterinc@aol.com>
Sent: Wednesday, May 12, 2021 9:22 AM
To: Cockrell, Joan
Subject: ACL Water Assn - CCR

Good Morning, Joan.

We had our Website updated with a link to take you directly to the CCR.

The direct link for this document is www.aclwaterassociation.com/ccr. If I need to email an updated Certification Form, please let me know! Have an awesome day!

Cindy Lewis
ACL WATER ASSOCIATION, INC
1182 Hwy 43 South
601-546-2322
aclwaterinc@aol.com
www.aclwaterassociation.com